

DYNAMIC CONTROL OF INTERMITTENT RENEWABLE ENERGY FLUCTUATIONS IN TWO-LAYER POWER GRIDS

Simona Olmi

Istituto dei Sistemi Complessi
CNR - Consiglio Nazionale delle Ricerche
50019 Sesto Fiorentino, Italy
simona.olmi@fi.isc.cnr.it

Carl H. Totz

Institut für Theoretische Physik
Technische Universität Berlin
10623 Berlin, Germany
carl.hendrik@web.de

Eckehard Schöll

Technische Universität Berlin
and Potsdam Institute
for Climate Impact Research
14412 Potsdam, Germany
schoell@physik.tu-berlin.de

Article history:

Received 31.10.2021, Accepted 25.11.2021

Abstract

In this work we model the dynamics of power grids in terms of a two-layer network, and use the Italian high voltage power grid as a proof-of-principle example. The first layer in our model represents the power grid consisting of generators and consumers, while the second layer represents a dynamic communication network that serves as a controller of the first layer. The dynamics of the power grid is modelled by the Kuramoto model with inertia, while the communication layer provides a control signal P_i^c for each generator to improve frequency synchronization within the power grid. We propose different realizations of the communication layer topology and of the control signal, and test the control performances in presence of generators with stochastic power output. When using a control topology that allows all generators to exchange information, we find that a control scheme aimed to minimize the frequency difference between adjacent nodes operates very efficiently even against the worst scenarios with the strongest perturbations. On the other hand, for a control topology where the generators possess the same communication links as in the power grid layer, a control scheme aimed at restoring the synchronization frequency in the neighborhood of the controlled node turns out to be more efficient.

Key words

Nonlinear complex networks, power grids, synchronization, stability analysis, control

1 Introduction

To reach the goal of limiting the global warming to substantially less than two degrees, integrating renewable and sustainable energy sources into the electrical power grid is essential [UNFCCC, 2015]. Wind and solar power are the most promising contributors to reach

a sustainable energy supply but their integration into the existing power transmission and distribution systems remains an enormous challenge [Vaccaro et al., 2011; Jacobson and Delucchi, 2011; Ueckerdt et al., 2015]. Recently, renewable energy generators, which produce a few kilowatts in the case of residential photovoltaic systems, up to some megawatts in the case of large photovoltaic and wind generators, have become widely dispersed around the world, thus transforming the present power system into a large-scale distributed generation system. The drawback of renewable energy power plants is that their output is subject to environmental fluctuations outside of human control, i.e., clouds blocking the sun or lack of wind, and these fluctuations emerge on all timescales displaying non-Gaussian behaviour [Heide et al., 2010; Milan et al., 2013; Anvari et al., 2016; Anvari et al., 2017; Auer et al., 2017]. In particular the power grid infrastructure is very critical [Witthaut et al., 2016]. Due to the design of the current power grid as a centralized system where the electric power flows unidirectionally through transmission and distribution lines from power plants to the customer, the control is concentrated in central locations and only partially in substations, while remote ends, like loads, are almost or totally passive. Therefore it is necessary to design more effective and widely distributed intelligent control embedded in local electricity production, two-way electricity and information flows, thus achieving flexible, efficient, economic, and secure power delivery [Liserre et al., 2010; Anvari et al., 2020].

A Smart Grid [Santacana et al., 2010] requires both a complex two-way communication infrastructure, sustaining power flow between intelligent components, and sophisticated computing and information technologies. In particular, control is needed in power networks in order to assure stability and to avoid power breakdowns

or cascading failures: one of the most important control goals is the preservation of synchronization within the whole power grid [Cornelius et al., 2013; Motter et al., 2013; Tegling and Sandberg, 2017; Carreras et al., 2020; Molnar et al., 2021; Tyloo and Jacquod, 2020]. Control mechanisms able to preserve synchronization are ordered by their time scale on which they act: the first second of the disturbance is mainly uncontrolled, and in this case a power plant will unexpectedly shut down with a subsequent shortage of power in the system, energy is drawn from the spinning reserve of the generators. Within the next seconds, the primary control sets on to stabilize the frequency and to prevent a large drop. Finally, to restore the frequency back to its nominal value of 50 (or 60) Hertz, secondary control is necessary. In many recent studies on power system dynamics and stability, the effects of control are completely neglected or only primary control is considered [Dörfler et al., 2013; Schäfer et al., 2018a; Rohden et al., 2012; Schäfer et al., 2015; Schäfer et al., 2016; Wang et al., 2016]. This control becomes less feasible if the percentage of renewable power plants increases, due to their reduced inertia [Ullbig et al., 2014; Doherty et al., 2009]. Few studies are devoted to secondary control [Weitenberg et al., 2018; Tchuisseu et al., 2018; Simpson-Porco et al., 2012] and to time-delayed feedback control [Okuno and Kawakita, 2006; Dongmo et al., 2017; Taher et al., 2019].

The aim of this work is to develop novel control concepts considering the communication infrastructure present in the smart grid. In applied nonlinear dynamics few works have included the communication layer into the modeling of power networks. Even though the communication infrastructure plays an important role in control and synchronization, preliminary works [Li and Han, 2011; Wei et al., 2012] assume trivial networks, without disconnected nodes, isolated generators, microgrids, or even coupled microgrids that can be connected or disconnected to the main grid at any time.

In this paper we consider a two-layer network in a full dynamic description [Totz et al., 2020]. It consists of a power grid layer and a communication layer, which provides the control for the power grid. Each layer is governed by its own dynamics, which is dependent upon the state of the other layer. In particular the physical topology that relates the interconnection of distributed generators and loads is described by coupled Kuramoto phase oscillators with inertia, derived from the swing equation [Filatrella et al., 2008], while the communication topology, which describes the information flow of the power system control measurements, depends on the information of the neighbors of each node [Giraldo et al., 2013]. Starting from the ideal synchronized state, we investigate the effect of a real threat to synchronization of the network: intermittent noise, which is used to describe the fluctuating power output of renewable energy power plants. For this perturbation different setups of the communication layer are tested to find an effective control strategy that successfully preserves frequency synchrono-

nization. As a proof of concept the Italian high voltage power grid is considered. The same two-layer topology has been investigated in [Buldyrev et al., 2010] to understand how localized events can present a severe danger to the stability of the whole power grid by causing a cascade of failures, but without considering the dynamics of the control nodes. In [Totz et al., 2020] we have investigated, within the same set-up, different perturbations to which the system is subject, e.g., failure of nodes, increased consumer demand, power plants subject to non-Gaussian or Gaussian white noise. Here we restrict ourselves to a more detailed analysis of intermittent power fluctuations, typical for renewable energy sources. Our proposed control techniques preserve synchronization for the implemented perturbations, thus demonstrating the powerful perspectives of our control approach which considers synchronization of power systems based on the coupled dynamics of the smart grid architecture and the communication infrastructure.

2 Model and Methods

Power grid layer. The Kuramoto model with inertia describes the phase and frequency dynamics of N coupled synchronous machines arranged in the controlled power grid layer, i.e., generators or consumers within the power grid, where mechanical and electrical phase and frequency are assumed to be identical:

$$m\ddot{\vartheta}_i(t) = -\dot{\vartheta}_i(t) + (\Omega_i + P_i^c(t)) + K \sum_j^N a_{ij}(t) \sin(\vartheta_j(t) - \vartheta_i(t)), \quad (1)$$

with the phase ϑ_i and frequencies $\dot{\vartheta}_i$ of node $i = 1, \dots, N$. Both dynamical variables $\vartheta_i, \dot{\vartheta}_i$ are defined relative to a frame rotating with the reference power line frequency (i.e., 50 or 60 Hz). The inherent frequency distribution is bimodal, where a positive natural frequency Ω_i of a node corresponds to the suitably normalized power supplied by a generator, while a negative natural frequency corresponds to the demand of a load. The power balance requires that the power supplied by all generators in the network is exactly met by the combined demand of all loads: $\sum_i \Omega_i = 0$. The additional term P_i^c denotes the control signal supplied by the communication layer, which serves as an offset to the power supplied by a controlled generator. For simplicity we assume homogeneously distributed transmission capacities K and inertia m . The adjacency matrix a_{ij} takes the value 1 if node i has a transmission line connected to node j , 0 otherwise. In our numerical simulations we use the Italian high voltage power grid topology [GENI, 2016], which consists of $N = 127$ nodes, of which 34 are generators and 93 are loads. The matrix a_{ij} , which describes the topology, is unweighted and symmetrical (see Fig. 1 (a) for graph details).

Macroscopic indicators and parameter regime. For our investigation we have chosen a regime of bistability




Figure 1. Visualisation of the topology of the individual layers of the two-layer power grid: (a) Topology a_{ij} of the power grid layer based on the real Italian high voltage power grid; (b) control layer topology c_{ij}^{loc} where the communication links of the generators are as in the power grid layer; (c) control layer topology c_{ij}^{ext} where generators possess additional communication links to all other generators in the network (green). Red nodes denote generators, while blue nodes denote consumers. Position of nodes has been slightly modified to improve readability.

in which both the fully frequency-synchronized state and a partially synchronized state are accessible. In this way it is possible to mimic the effect of a perturbation applied to the synchronized state: this displaces the system out of synchrony into an intermediate state where the operating conditions are not optimal for the functioning of power grids. For a detailed analysis of the system in absence of control see [Olm et al., 2014; Tumash et al., 2018; Totz et al., 2020]. For each numerical experiment, the system evolves for a transient time t_R , until the network settles and it reaches a steady state. At this point, characteristic measures are calculated, averaging over a time t_A , in order to assess the level of synchronization of the state $\{\vartheta_i(t_R), \dot{\vartheta}_i(t_R)\}$. In particular the time-averaged phase velocity profile $\langle \omega_i \rangle_t \equiv \langle \dot{\vartheta}_i \rangle_t$ provides information about the frequency synchronization of each node, while the standard deviation of the frequencies

$$\Delta\omega(t) = \sqrt{\frac{1}{N} \sum_j^N (\omega_j(t) - \bar{\omega}(t))^2} \quad (2)$$

gives information about the deviation from complete frequency synchronization at the macroscopic level ($\bar{\omega}(t)$ represents the instantaneous ensemble-averaged grid frequency). The phase ordering of the power grid is measured by the complex order parameter

$$R(t)e^{i\Phi(t)} = \frac{1}{N} \sum_{j=1}^N e^{i\vartheta_j}, \quad (3)$$

where the modulus $R(t) \in [0, 1]$ and the argument $\Phi(t)$ indicate the degree of synchrony and mean phase angle, respectively. In the following we will denote $R(t)$ as *global order parameter*. In the continuum limit an

asynchronous state is characterized by $R \approx 0$, while $R = 1$ corresponds to full phase synchronization. Intermediate values of R correspond to states with partial or cluster synchronization. In this article we explore the dynamics of the system at $K = 6.5$, where the system shows bistability between full frequency synchronization (i.e., it corresponds to the minimum coupling strength for which full frequency synchronization is still achievable) and partial synchronization ($\langle \Delta\omega \rangle_t \simeq 1.6$), which models the resulting state when the power grid is strongly perturbed.

Communication layer. The smart grid includes a communication infrastructure in all the stages of the power system, from transmission to users, allowing for the design of control strategies based on the information data flow. In real applications, we need to consider isolated elements, where synchronization needs to be assured such that, if the isolated nodes are reconnected to the main power system, failures can be avoided and the stability of the network is preserved. Therefore, the use of a communication layer of the network may improve the performance of the power system. We consider two layer topologies or infrastructures, the physical topology that describes the power system dynamics (as shown in Fig. 1 (a)), and the communication layer topology, which describes how data from each node is transmitted (see Fig. 1 (b), (c) for the topologies of the communication layer investigated here). Both infrastructures can be conceived as a multilayer network.

To design a control strategy for synchronization, it is necessary to collect information from each generator and its neighbors. Phasor measurement units or sensors provide information, such that local controllers integrated with the generator nodes use the information to calculate

a control signal $P_i^c \in \mathbb{R}$. The loads are not controlled. The control signal can be interpreted as power injection for positive P_i^c or power absorption for negative values of P_i^c , which is realized using storage devices (e.g., batteries) that can absorb or inject power to the generator buses [Qian et al., 2010]. This real-world framework can be translated in terms of Eq. (1) as injecting power in steady state operation.

Since the communication layer describes the exchange of information between the nodes about their current dynamic states, we consider a control strategy that depends on the information of the neighbors of each node, from which a control signal $P_i^c(t)$ for each controlled node is calculated dynamically. Neighbors can be related using the adjacency matrix $\mathcal{C} = \{c_{ij}\}$ of the communication layer. Our essential point is that we equip the communication layer also with a dynamics of its own. Therefore we propose to determine the control signal $P_i^c(t)$ by a first order differential equation depending on the frequencies $\dot{\vartheta}_j$ of neighboring nodes within the communication layer c_{ij} :

$$\dot{P}_i^c(t) = G_i f_i \left(c_{ij}, \{ \dot{\vartheta}_j(t) \} \right), \quad (4)$$

where G_i is the control strength and f_i represents the control function. In particular we assume that it is possible to control only the power output of generators in the network, thus G_i is zero for all loads:

$$G_i = \begin{cases} G, & i \in M_{gen} \\ 0, & \text{otherwise} \end{cases} \quad (5)$$

where M_{gen} is the set of all generators in the network. Throughout this work we choose $G = 0.04$. Two different topologies have been considered for the communication layer, namely c_{ij}^{loc} and c_{ij}^{ext} . In the local topology c_{ij}^{loc} the connections between each generator and the other nodes in the communication layer correspond to the connections in the power grid layer (i.e., the communication layer network consists of a subnetwork of the power grid layer which contains all links of the generators in the power grid), except that each node has available also the information about itself, so that the diagonal elements of the adjacency matrix are nonzero. The local topology is thus described by the adjacency matrix

$$c_{ij}^{loc} = \begin{cases} 1, & i = j \\ a_{ij}, & \text{otherwise} \end{cases}. \quad (6)$$

As only generators receive a control signal P_i^c , all loads which are not connected to a generator can be disregarded in the communication layer, as illustrated in Fig. 1 (b).

For the extended control topology c_{ij}^{ext} additional links between all generators are present (see Fig. 1 (c)). The globally coupled generators represent a subset of the communication layer (which additionally contains the

neighboring loads); this provides an exchange of information between all generator control stations. The corresponding connectivity matrix is defined as

$$c_{ij}^{ext} = \begin{cases} 1, & i \wedge j \in M_{gen} \\ c_{ij}^{loc}, & \text{otherwise} \end{cases}. \quad (7)$$

As shown in Eq. (4), the dynamics of the control signal is governed by the control function $f_i \left(c_{ij}, \{ \dot{\vartheta}_j \} \right)$. In this work we consider three different control functions: the first one is to apply a control signal that is proportional to the frequency difference between node i and its neighbors [Giraldo et al., 2013]

$$f_i^{diff} \left(c_{ij}, \{ \dot{\vartheta}_j(t) \} \right) = \sum_j^N c_{ij} \left(\dot{\vartheta}_j(t) - \dot{\vartheta}_i(t) \right). \quad (8)$$

We refer to this control scheme as *difference control*. In control theory this control function is known as proportional control [Bequette, 2003]. However, when considering a control proportional to the frequency error difference, we can also refer to it as frequency droop control [De Brabandere et al., 2007] or diffusive coupling [Hale, 1997], depending on the addressed community (i.e., power systems control or circuit theory, respectively).

The second approach is to apply a control signal that aims to restore power balance in the neighborhood of the controlled node:

$$f_i^{dir} \left(c_{ij}, \{ \dot{\vartheta}_j(t) \} \right) = -\frac{1}{N_i} \sum_j^N c_{ij} \dot{\vartheta}_j(t). \quad (9)$$

Here N_i gives the number of direct neighbors of node i in c_{ij} . We will call this control scheme *direct control*. A control scheme proportional to the absolute frequency error is referred to as proportional control in control theory [Bequette, 2003].

The final control scheme is a combination of both difference and direct control:

$$f_i^{comb} \left(c_{ij}, \{ \dot{\vartheta}_j(t) \} \right) = \sum_j^N c_{ij} \left(a \left(\dot{\vartheta}_j(t) - \dot{\vartheta}_i(t) \right) - b \frac{\dot{\vartheta}_j(t)}{N_i} \right). \quad (10)$$

Here a and b are weight factors of the two components. In all further instances we will assume that $a = b = 1$. We will refer to this control scheme as *combined control*.

Perturbation: Generation of intermittent noise.

Due to atmospheric turbulence, wind power has specific turbulent characteristics [Milan et al., 2013; Anvari et al., 2016; Anvari et al., 2017; Auer et al., 2017], such as extreme events, time correlations, Kolmogorov power

spectrum, and intermittent increment statistics. In particular the increment probability density functions of real wind power data significantly deviate from Gaussianity and its power spectrum displays (5/3)-decay with some discrepancy in the high frequency range. Based on this, we generate intermittent power time series $x(t)$ according to the synthetique feed-in noise generation detailed by Schmietendorf et al. in [Schmietendorf et al., 2017]. The first step in generating the intermittent noise time series is to consider the dynamics of the following Langevin-type system of equations:

$$\dot{z}(t) = z(t) \left(g - \frac{z(t)}{z_0} \right) + \sqrt{Iz^2(t)}y(t), \quad (11)$$

$$\dot{y}(t) = -\gamma y(t) + \xi(t), \quad (12)$$

where $y(t)$ represents colored noise generated by an Ornstein–Uhlenbeck process [Gillespie, 1996; Ricciardi and Sato, 1988] with a correlation time $\tau_{OU} = 1/\gamma$ and with a δ -correlated Gaussian white noise term ξ . The parameter I controls the intermittency strength, while the other parameters $\gamma = 1.0$, $g = 0.5$ and $z_0 = 2.0$ are chosen as in [Schmietendorf et al., 2017]. In a second step the time series $z(t)$ is transformed, so that its power spectrum resembles more closely the power spectrum of wind power plants. To achieve this, the Fourier transform $X(f) = FT[z(t)](f)$ is first divided by its amplitude spectrum. This process eliminates the amplitude information of $X(f)$, but retains its phase information. Subsequently a weight function $h(f)$ is used in order to make the spectrum of the series similar to the empirical data:

$$\hat{X}(f) = \frac{X(f)}{|X(f)|} h^{\frac{1}{2}}(f). \quad (13)$$

The power spectrum of $\hat{X}(f)$ is proportional to the weight function. Finally \hat{X} is transformed back into the time domain: $\tilde{x}(t) = FT^{-1}[\hat{X}(f)](t)$. Due to the elimination of amplitude information, the amplitude of \tilde{x} is freely scalable. The standard deviation $\sigma_{\tilde{x}}$ of the aggregated distribution of \tilde{x} is rescaled to any desired σ_x :

$$x(t) = \frac{\sigma_x}{\sigma_{\tilde{x}}} \tilde{x}(t). \quad (14)$$

Since $\langle x(t) \rangle = 0$, $\langle \Omega_i(t) \rangle = \Omega_{gen}$ and power balance is maintained on long-time average.

Further restrictions are introduced to make this perturbation more realistic. A lower boundary for x is introduced, so that a generator cannot operate as a load in the network due to the influence of noise: all values $x < -1$ are truncated to $x = -1$. Furthermore a power feed-in cut-off is assumed, which means that generators have a maximum power output they can supply: all values $x > 1$ are truncated to $x = 1$. This additionally truncates some of the extreme events in the strongly intermittent power time series, while the mean and standard deviation are nonetheless almost unaffected by this. With

these constraints for x , the penetration parameter μ is chosen equal to the natural frequency Ω_i of the affected generator to prevent any generator from acting as a load and giving a maximum power feed-in to the network. Throughout this work we fix $I = 2$, $h(f) = f^{-\frac{5}{3}}$ and $\sigma_x = \frac{1}{3}$ for intermittent noise.

3 Results

A characteristic feature of renewable energy sources are power fluctuations due to fluctuating wind and solar irradiation (clouds). This requires novel design concepts and theoretical investigations into smart storage control strategies to balance feed-in variations and mitigate power quality problems induced by stochastic fluctuations. A particular challenge for stable power grid operation is given by wind- and solar-induced fluctuations, which follow characteristic non-Gaussian statistics over a broad band of time scales from seasonal and diurnal imbalances down to short-term fluctuations on the scale of seconds and sub-seconds [Anvari et al., 2016]. The turbulent character of wind feed-in, and in particular its intermittency, is directly transferred into frequency and voltage fluctuations, as shown in [Schmietendorf et al., 2017], where the main characteristics of real wind feed-in were captured by generating intermittent time series on the basis of a Langevin-type model and imposing a realistic power spectrum. In the following we systematically investigate the effect of applying intermittent noise to each individual generator (*single node perturbation*).

When the perturbation is applied systematically to each individual generator in the network in the absence of control, we observe that the whole network always loses synchronization, irrespectively of the targeted node (Figs. 2,3). Only few generators in the north-east of Italy are resilient to perturbation, as exemplified in Fig. 2 (middle panel). Due to the perturbation, the frequencies of the southern part of the Italian grid (index $i > 70$) usually start fluctuating with slightly negative frequencies, while the frequencies of the northern part fluctuate correspondingly with slightly positive frequencies. This behavior emerges during the perturbation and remains even after the perturbation ends. However generators do not usually desynchronize from the rest of the power grid, apart from a few cases (i.e., nodes $i=86, 115$), which correspond to dead ends. Moreover fluctuations affect the network with a different timing, depending on the topological location: if a node belonging to the southern part of the network is targeted, the network loses synchronization almost immediately; if a node belonging to the north-western part of the power grid is targeted, the power grid eventually loses frequency synchronization after some time $t \sim T_p/2$ where T_p is the duration of the perturbation. Only the generators in the north-eastern part of the power grid ($i = 39, 40, 49, 52, 56, 68, 69$) remain resilient as highlighted in Fig.2 by an orange circle. This also shows up in the left-hand side of Fig.3,




Figure 2. Frequency synchronization of the network is vulnerable to disruption of nodes depending on their location: Applying intermittent noise to any generator outside the orange circle is critical to frequency synchronization. Generators are marked by red dots, while blue dots indicate loads. Space-time plots of the network, for 3 different perturbed nodes, are shown in the left column. Color indicates the instantaneous frequency $\dot{\vartheta}$ of the nodes, where the horizontal dashed lines mark the onset and the end of the perturbation. Each panel is labeled by the number of the perturbed node in brackets. Coupling strength $K = 6.5$, inertial mass $m = 10$, bimodal frequency (power) distribution $\Omega_{load} = -1$ and $\Omega_{gen} = \frac{93}{34}$. Integration time step $\Delta t = 0.002$.

which presents the space-time plots of the instantaneous frequencies if generator (i), whose number is given in the legend of the respective panel, is perturbed (left panels).

In Fig. 4(a), (b) the ability of the different control schemes to preserve frequency synchronization in the presence of the perturbation is illustrated. *Difference control* is only effective in counteracting the perturbation if additional links between the generators are present in the communication layer, while *direct control* is only effective in the absence of additional connections. As detailed in Fig. 5, when applying *difference control* to a sparse control network (i.e. generators in the control layer are connected just to their direct neighbors), the underlying power grid is unable to recover full frequency synchronization after the perturbation ends, since the frequency shift between the northern and the southern parts remains unchanged. If the generators in the control layer are globally connected (Fig. 6), full frequency synchronization is always achieved after the end of the perturbation with *difference control*, except if node $i = 73$ is perturbed: in this case short-living fluctuations emerge, on a time $t \sim 150$, that possess an intensity of $\Delta\omega \sim 0.2$. On the other hand, the application of *direct control* to a local control layer topology (Fig. 5) allows for the achievement of full frequency synchronization at the end of the perturbation. Moreover full frequency synchronization is mostly retained even during the perturbation, irrespectively of short-living fluctuations comprising the whole network that emerge for a time $t \sim 100$. When *direct*

control is applied to the extended control layer topology (Fig. 6), the frequency synchronization is not retained during the perturbation and a frequency shift between the northern and southern parts emerges. Finally, *combined control* is as effective as the more efficient of its two components depending on topology, as the ineffective component is mostly inactive.

In addition to targeting each individual generator in the network with different perturbations, we now investigate the impact of targeting several generators simultaneously (*multiple node perturbation*). For this purpose we systematically increase the number n of targeted generators. As shown in Fig. 3 (right panels), generators are perturbed successively from south to north along the Italian grid: the perturbation first affects nodes in the southern part of the network (characterized by higher node index), and generators with decreasing node index are added successively, one by one, to the list of the perturbed nodes. Thus the perturbation propagates from the south to the north of Italy. If intermittent noise is applied to multiple generators, we generally observe a frequency shift between northern and southern parts with stronger fluctuations at the boundary of the two parts (Fig. 3). When the perturbation ends, the shift may persist, or single-node desynchronization may occur. In particular if generators close to the boundary are perturbed (i.e., $i = 76, 71$), for $11 \leq n \leq 15$ the fluctuations across the network persist after the end of the perturbation, and a single generator desynchronizes, $i = 71$. The remaining network recovers frequency synchronization. Fig. 7 shows the impact of applying different control schemes to an increasing number of generators subject to intermittent noise. We observe, in agreement with the case where single generators are targeted, that *direct control* is the most effective control scheme in the absence of additional links between the generators in the control layer (as detailed in Fig. 8). However, the frequency deviation induced by the perturbation is the larger, the more nodes are affected simultaneously. Thus the reliability of *direct control* deteriorates with the severity of the perturbation. In the case of multiple generators connected in a chain, *direct control* can lead to runaway desynchronization, as the middle generator tries to compensate for its two neighbors which in turn act to compensate for the middle generator. Therefore, if one generator adopts a negative frequency, while the other has a positive frequency, *direct control* will only ensure that their amplitudes are similar, as it only acts to restore the mean frequency in the neighborhood of the controlled node to the nominal frequency of the network. *Difference control* by itself is ineffective in restoring synchronization during the time of perturbation without additional links between the generators in the communication layer, but it becomes very effective at preserving frequency synchronization within the power grid, if all generators are connected in the communication layer (as detailed in Fig. 9). In the absence of additional links in the communication layer, *combined control* is governed by the inter-




Figure 3. Space-time plots of the network, when a single generator (left) or multiple generators (right) are subjected to intermittent noise with $\mu = \frac{93}{34}$. Node index i on the x-axis and time t on the y-axis. Left panels: the index i of the affected generator is noted in the upper right corner of each panel. Right panels: The number n of affected generators is noted in the upper right corner of each panel. Dashed horizontal lines indicate the starting time t_{start} and ending time t_{end} of the perturbation, respectively. Parameters $\mu = \Omega_{gen}$, $\sigma_x = \frac{1}{3}$, $I = 2$, $h(f) = f^{-\frac{3.5}{5}}$, $g = 0.5$, $z_0 = 2$, $\gamma = 1$.




Figure 4. Control of frequency synchronization for intermittent noise targeting a single node: Mean standard deviation of frequency during the time of perturbation $\langle \Delta\omega \rangle_{T_p}$ vs the index i of the targeted node. The symbols indicate different control schemes. Blue squares: no control. Red triangles: *difference control*. Yellow circles: *direct control*. Green diamonds: *combined control*. Control strength: $G = 0.04$. The two panels show different control layer topologies: The left panel (a) shows the simple setup (C_{ij}^{loc}) of the control layer, where generators possess the same connections as in the power grid layer, and the right panel (b) shows a control layer topology (C_{ij}^{ext}) where additional links between all generators are present. Parameters as in Fig. 3.

play of its two components (Figs. 7, 8): the *difference control* is preventing the *direct control* from stabilizing an equilibrium between the generators that is far from frequency synchronization, which greatly improves the effectiveness of merely *direct control*. In the presence of

additional links between the generators in the communication layer (Figs. 7, 9) the dynamics of *direct control* is again mostly dominated by its *difference control* component.

4 Conclusion

The control of intermittent energy fluctuations in power grids is of great current interest in view of the impending termination of nuclear and fossil-fuel energy and replacement of old power plants with renewable energy sources [UNFCCC, 2015]. Wind and photovoltaic power are the most promising technologies, but their integration into the grid poses a challenge [Jacobson and Delucchi, 2011; Turner, 1999; Ueckerdt et al., 2015], in particular due to the fluctuation features of renewable power generators [Anvari et al., 2016; Anvari et al., 2017; Auer et al., 2017; Schmietendorf et al., 2017] and the impact of energy trading on the network [Schäfer et al., 2018a; Ritmeester and Meyer-Ortmanns, 2021]. In this work, we have investigated the controllability of a power grid against intermittent noise using the Italian grid as proof-of-principle. We have presented a novel approach by considering the dynamics of a power grid in




Figure 5. Space-time plots of the network, when a single generator is subject to intermittent noise. Generators are controlled by difference-control (left), direct-control (center), combination-control (right) in the local control topology C_{ij}^{loc} . Node index i on the x-axis and time t on the y-axis. Color indicates the frequency $\hat{\nu}$. The index i of the affected generator is noted in the upper right corner of each panel. Dashed horizontal lines indicate t_{start} and t_{end} respectively. Parameters as in Fig. 3.




Figure 6. Space-time plots of the network, when a single generator is subject to intermittent noise. Generators are controlled by difference control (left), direct control (center), combined control (right) in the extended control topology C_{ij}^{ext} . Node index i on the x-axis and time t on the y-axis. Color indicates the frequency $\hat{\nu}$. The index i of the affected generator is noted in the upper right corner of each panel. Dashed horizontal lines indicate t_{start} and t_{end} , respectively. Parameters as in Fig. 3.

a two-layer network model, using a fully dynamical description for the communication layer. Specifically, here we have modelled the Italian high voltage power grid as a dynamical two-layer network, where the dynamics of the power grid layer is described in terms of the second order Kuramoto model with inertia. On the other hand the second layer, which represents the communication network, models the dynamic control signal for each generator. To describe the fluctuating power output of renewable energy power plants realistic intermittent noise

has been used. Previous investigations of multiple-layer power grids have been performed by taking into account only static nodes without dynamics, focusing on topological effects [Buldryev et al., 2010]. On the other hand, investigations of the dynamics of the (Italian) power grid are usually conducted only in a single layer [Corsi et al., 2004; Fortuna et al., 2012; Olmi et al., 2014; Tumash et al., 2019; Mehrmann et al., 2018; Taher et al., 2019], as well as the investigation of the dynamics of cascading




Figure 7. Control of frequency synchronization for intermittent noise targeting multiple nodes: Mean standard deviation of frequency during the time of perturbation $\langle \Delta\omega \rangle_{T_p}$ vs the number n of targeted nodes. The symbols indicate different control schemes. Blue squares: no control. Red triangles: *difference control*. Yellow circles: *direct control*. Green diamonds: *direct control*. Control strength $G = 0.04$. The two panels show different control layer topologies: (a) c_{ij}^{loc} , (b) c_{ij}^{ext} . Parameters of the perturbations as in Fig. 4. In the inset an enlargement is provided.

failures [Schäfer et al., 2018b].

In the communication layer we have investigated a selection of different control schemes (control functions f_i^{diff} , f_i^{dir} and f_i^{comb}) and control topologies (adjacency matrices c_{ij}^{loc} and c_{ij}^{ext}). All control schemes take advantage of the second layer by collecting information from adjacent nodes described by c_{ij} to calculate the control signal. This can be done either in a local setting (c_{ij}^{loc}) where generators possess the same communication links as in the power grid layer, or in an extended control layer topology (c_{ij}^{ext}) where additional communication links between all generators are present. We have tested (i) a control scheme aimed at synchronizing the frequency of the controlled nodes with their neighbors (difference control f_i^{diff}), (ii) a control scheme aimed at restoring the original synchronization frequency in the neighborhood of the controlled node (direct control f_i^{dir}), and (iii) a mixed approach combining both (f_i^{comb}). *Difference control* proves ineffective in the local control topology c_{ij}^{loc} , because it is only able to improve frequency synchronization locally. This means that if a perturbation causes the northern and southern part of the network to lose synchronization, the control scheme only suppresses local fluctuations in the northern and southern part separately, but does not restore frequency synchronization between the two parts of the power grid: no generator is sufficiently connected to both parts simultaneously to make the control scheme effective. However, this shortcoming is removed when we consider the extended control topology. In particular, when additional communication links are introduced in c_{ij}^{ext} , all generators become well connected to both the northern and southern part of the grid, enabling the control to restore frequency synchronization across the whole grid. *Direct control* proves to be more effective in the local control topology c_{ij}^{loc} , where less communication links are present than in c_{ij}^{ext} . This is due to the basis mechanism underlying *direct control*: it compensates the deviation of the mean frequency of all nodes connected to the controlled generator, thus causing the con-

trol to remain inactive when the mean frequency matches the nominal frequency of the power grid, while not all nodes are frequency synchronized. Adding further communication links in the control topology renders the control scheme ineffective as multiple controlled generators compensate each other instead of restoring the nominal frequency within the power grid. *Combined control* in the local control topology c_{ij}^{loc} is governed by its *direct control* component. Since synchronization is lost across the grid, but not locally, *difference control* is mostly inactive, while the *direct control* part is responsible for restoring synchronization within the grid. When additional communication links between the generators are present (i.e. c_{ij}^{ext}), the combined control is dominated by its *difference control* component. In this case the *direct control* is mostly inactive since the mean frequency across the two desynchronized regions of the network is equal to the nominal frequency.

The investigation of the self-emerging control dynamics following perturbations has highlighted the role played by some specific nodes: dead-ends and dead-trees result to be always problematic, in agreement with recent work [Menck et al., 2014; Auer et al., 2017] where it has been demonstrated that the cost-minimizing creation of dead-end or dead-tree structures increases the vulnerability of the power grid to large perturbations. The role of solitary nodes has recently been emphasized [Taher et al., 2019; Hellmann et al., 2020; Berner et al., 2021]. Moreover, it turns out that the Italian power grid can be divided in two specific parts: the northern, continental part, with a higher average connectivity, which is more resilient to perturbations, and the southern, peninsular part, characterized by a low average connectivity. The elongated structure of the southern part makes it less robust to perturbations. These results are in agreement with previous findings by [Totz et al., 2020], where also other realistic perturbation scenarios were applied.

Further work should incorporate time delay in the dynamics of the control grid, accounting for the delay in detecting the frequency of the generators and the delays during communication between them. Furthermore it would be interesting to investigate different topologies in the communication layer, which may be distinct from the underlying power grid topology (such as random networks).

Acknowledgements

The authors acknowledge Enrico Steinfeld and Katrin Schmietendorf for useful discussions. Funded by the Deutsche Forschungsgemeinschaft (DFG, German Research Foundation) - Projektnummer 163436311 - SFB 910.

References

Anvari, M., Hellmann, F., and Zhang, X. (2020). Introduction to focus issue: Dynamics of modern power grids. *Chaos*, **30** (6), pp. 063140.




Figure 8. Space-time plots of the network, when multiple generators are subject to intermittent noise. Generators are controlled by difference-control (left), direct-control (center), combination-control (right) in the local control topology C_{ij}^{loc} . Node index i on the x-axis and time t on the y-axis. Color indicates the frequency $\hat{\nu}$. The number n of the affected generators is noted in the upper right corner of each panel. Dashed horizontal lines indicate t_{start} and t_{end} respectively. Parameters as in Fig. 3.




Figure 9. Space-time plots of the network, when multiple generators are subject to intermittent noise. Generators are controlled by difference-control (left), direct-control (center), combination-control (right) in the extended control topology C_{ij}^{ext} . Node index i on the x-axis and time t on the y-axis. Color indicates the frequency $\hat{\nu}$. The number n of the affected generators is noted in the upper right corner of each panel. Dashed horizontal lines indicate t_{start} and t_{end} respectively. Parameters as in Fig. 3.

Anvari, M., Lohmann, G., Wächter, M., Milan, P., Lorenz, E., Heinemann, D., Tabar, M. R. R., and Peinke, J. (2016). Short term fluctuations of wind and solar power systems. *New J. Phys.*, **18**(6), pp. 063027.

Anvari, M., Wächter, M., and Peinke, J. (2017). Phase locking of wind turbines leads to intermittent power production. *EPL*, **116**(6), pp. 60009.

Auer, S., Hellmann, F., Krause, M., and Kurths, J. (2017). Stability of synchrony against local intermittent fluctuations in tree-like power grids. *Chaos*,

27(12), pp. 127003.

Bequette, B. W. (2003). *Process control: modeling, design, and simulation*. Prentice Hall Professional.

Berner, R., Yanchuk, S., and Schöll, E. (2021). What adaptive neuronal networks teach us about power grids. *Phys. Rev. E*, **103**(4), pp. 042315.

Buldyrev, S. V., Parshani, R., Paul, G., Stanley, H. E., and Havlin, S. (2010). Catastrophic cascade of failures in interdependent networks. *Nature*, **464**(7291),

- pp. 1025–1028.
- Carreras, B. A., Tchawou Tchuisseu, E. B., Reynolds-Barredo, J. M., Gomila, D., and Colet, P. (2020). Effects of demand control on the complex dynamics of electric power system blackouts. *Chaos*, **30**(11), pp. 113121.
- Cornelius, S. P., Kath, W. L., and Motter, A. E. (2013). Realistic control of network dynamics. *Nature Comm.*, **4**(1), pp. 1–9.
- Corsi, S., Pozzi, M., Sabelli, C., and Serrani, A. (2004). The coordinated automatic voltage control of the italian transmission grid-part i: reasons of the choice and overview of the consolidated hierarchical system. *IEEE Transactions on power systems*, **19**(4), pp. 1723–1732.
- De Brabandere, K., Bolsens, B., Van den Keybus, J., Woyte, A., Driesen, J., and Belmans, R. (2007). A voltage and frequency droop control method for parallel inverters. *IEEE Trans. on power electronics*, **22**(4), pp. 1107–1115.
- Doherty, R., Mullane, A., Nolan, G., Burke, D. J., Bryson, A., and O'Malley, M. (2009). An assessment of the impact of wind generation on system frequency control. *IEEE Trans. on Power Systems*, **25**(1), pp. 452–460.
- Dongmo, E. D., Colet, P., and Wofo, P. (2017). Power grid enhanced resilience using proportional and derivative control with delayed feedback. *The European Physical Journal B*, **90**(1), pp. 1–10.
- Dörfler, F., Chertkov, M., and Bullo, F. (2013). Synchronization in complex oscillator networks and smart grids. *Proc. Natl. Acad. Sciences*, **110**(6), pp. 2005–2010.
- Filatrella, G., Nielsen, A. H., and Pedersen, N. F. (2008). Analysis of a power grid using a kuramoto-like model. *Eur. Phys. J. B*, **61**(4), pp. 485–491.
- Fortuna, L., Frasca, M., and Sarra Fiore, A. (2012). A network of oscillators emulating the italian high-voltage power grid. *Int. J. Mod. Phys. B*, **26**(25), pp. 1246011.
- GENI (2016). Geni - global energy network institute: *Map of Italian Electricity Grid*, available at https://www.geni.org/globalenergy/library/national_energy_grid/italy/italiannationalelectricitygrid.shtml.
- Gillespie, D. T. (1996). Exact numerical simulation of the ornstein-uhlenbeck process and its integral. *Phys. Rev. E*, **54**(2), pp. 2084.
- Giraldo, J., Mojica-Nava, E., and Quijano, N. (2013). Synchronization of dynamical networks with a communication infrastructure: A smart grid application. In *52nd IEEE Conference on Decision and Control*, IEEE, pp. 4638–4643.
- Hale, J. K. (1997). Diffusive coupling, dissipation, and synchronization. *J. Dynamics and Differential Equations*, **9**(1), pp. 1–52.
- Heide, D., Von Bremen, L., Greiner, M., Hoffmann, C., Speckmann, M., and Bofinger, S. (2010). Seasonal optimal mix of wind and solar power in a future, highly renewable europe. *Renewable Energy*, **35**(11), pp. 2483–2489.
- Hellmann, F., Schultz, P., Jaros, P., Levchenko, R., Kapitaniak, T., Kurths, J., and Maistrenko, Y. (2020). Network-induced multistability through lossy coupling and exotic solitary states. *Nature Comm.*, **11**(1), pp. 1–9.
- Jacobson, M. Z. and Delucchi, M. A. (2011). Providing all global energy with wind, water, and solar power, part i: Technologies, energy resources, quantities and areas of infrastructure, and materials. *Energy policy*, **39**(3), pp. 1154–1169.
- Li, H. and Han, Z. (2011). Synchronization of power networks without and with communication infrastructures. In *2011 IEEE International Conference on Smart Grid Communications (SmartGridComm)*, IEEE, pp. 463–468.
- Liserre, M., Sauter, T., and Hung, J. Y. (2010). Future energy systems: Integrating renewable energy sources into the smart power grid through industrial electronics. *IEEE Industrial Electronics Magazine*, **4**(1), pp. 18–37.
- Mehrmann, V., Morandin, R., Olmi, S., and Schöll, E. (2018). Qualitative stability and synchronicity analysis of power network models in port-hamiltonian form. *Chaos*, **28**(10), pp. 101102.
- Menck, P. J., Heitzig, J., Kurths, J., and Schellnhuber, H. J. (2014). How dead ends undermine power grid stability. *Nature Comm.*, **5**(1), pp. 1–8.
- Milan, P., Wächter, M., and Peinke, J. (2013). Turbulent character of wind energy. *Phys. Rev Lett.*, **110**(13), pp. 138701.
- Molnar, F., Nishikawa, T., and Motter, A. E. (2021). Asymmetry underlies stability in power grids. *Nature Comm.*, **12**(1), pp. 1–9.
- Motter, A. E., Myers, S. A., Anghel, M., and Nishikawa, T. (2013). Spontaneous synchrony in power-grid networks. *Nature Physics*, **9**(3), pp. 191–197.
- Okuno, H. and Kawakita, M. (2006). Delayed feedback control of three-synchronous-generator infinite-bus system. *Electrical Engineering in Japan*, **156**(1), pp. 7–12.
- Olmi, S., Navas, A., Boccaletti, S., and Torcini, A. (2014). Hysteretic transitions in the kuramoto model with inertia. *Phys. Rev. E*, **90**(4), pp. 042905.
- Qian, H., Zhang, J., Lai, J.-S., and Yu, W. (2010). A high-efficiency grid-tie battery energy storage system. *IEEE Trans. on power electronics*, **26**(3), pp. 886–896.
- Ricciardi, L. M. and Sato, S. (1988). First-passage-time density and moments of the ornstein-uhlenbeck process. *J. Appl. Probability*, **25**(1), pp. 43–57.
- Ritmeester, T. and Meyer-Ortmanns, H. (2021). Minority games played by arbitrageurs on the energy market. *Physica A*, **573**, pp. 125927.
- Rohden, M., Sorge, A., Timme, M., and Witthaut, D. (2012). Self-organized synchronization in decentralized power grids. *Phys. Rev. Lett.*, **109**(6), pp. 064101.

- Santacana, E., Rackliffe, G., Tang, L., and Feng, X. (2010). Getting smart. *IEEE power and energy magazine*, **8** (2), pp. 41–48.
- Schäfer, B., Beck, C., Aihara, K., Witthaut, D., and Timme, M. (2018a). Non-gaussian power grid frequency fluctuations characterized by lévy-stable laws and superstatistics. *Nature Energy*, **3** (2), pp. 119–126.
- Schäfer, B., Grabow, C., Auer, S., Kurths, J., Witthaut, D., and Timme, M. (2016). Taming instabilities in power grid networks by decentralized control. *Eur. Phys. J. Special Topics*, **225** (3), pp. 569–582.
- Schäfer, B., Matthiae, M., Timme, M., and Witthaut, D. (2015). Decentral smart grid control. *New J. Physics*, **17** (1), pp. 015002.
- Schäfer, B., Witthaut, D., Timme, M., and Latora, V. (2018b). Dynamically induced cascading failures in power grids. *Nature communications*, **9** (1), pp. 1975.
- Schmietendorf, K., Peinke, J., and Kamps, O. (2017). The impact of turbulent renewable energy production on power grid stability and quality. *Eur. Phys. J. B*, **90** (11), pp. 1–6.
- Simpson-Porco, J. W., Dörfler, F., and Bullo, F. (2012). Droop-controlled inverters are kuramoto oscillators. *IFAC Proceedings Volumes*, **45** (26), pp. 264–269.
- Taher, H., Olmi, S., and Schöll, E. (2019). Enhancing power grid synchronization and stability through time-delayed feedback control. *Phys. Rev. E*, **100** (6), pp. 062306.
- Tchuisseu, E. B. T., Gomila, D., Colet, P., Witthaut, D., Timme, M., and Schäfer, B. (2018). Curing braess' paradox by secondary control in power grids. *New J. Phys.*, **20** (8), pp. 083005.
- Tegling, E. and Sandberg, H. (2017). On the coherence of large-scale networks with distributed pi and pd control. *IEEE Contr. Syst. Lett.*, **1** (1), pp. 170–175.
- Totz, C. H., Olmi, S., and Schöll, E. (2020). Control of synchronization in two-layer power grids. *Phys. Rev. E*, **102** (2), pp. 022311.
- Tumash, L., Olmi, S., and Schöll, E. (2018). Effect of disorder and noise in shaping the dynamics of power grids. *EPL*, **123** (2), pp. 20001.
- Tumash, L., Olmi, S., and Schöll, E. (2019). Stability and control of power grids with diluted network topology. *Chaos*, **29** (12), pp. 123105.
- Turner, J. A. (1999). A realizable renewable energy future. *Science*, **285** (5428), pp. 687–689.
- Tyloo, M. and Jacquod, P. (2020). Primary control effort under fluctuating power generation in realistic high-voltage power networks. *IEEE Contr. Syst. Lett.*, **5** (3), pp. 929–934.
- Ueckerdt, F., Brecha, R., and Luderer, G. (2015). Analyzing major challenges of wind and solar variability in power systems. *Renewable energy*, **81**, pp. 1–10.
- Ulbig, A., Borsche, T. S., and Andersson, G. (2014). Impact of low rotational inertia on power system stability and operation. *IFAC Proceedings Volumes*, **47** (3), pp. 7290–7297.
- UNFCCC (2015). 21st conf. of the United Nations Framework, Convention on Climate: *Adoption of the Paris Agreement FCCC/CP/2015/L. 9/Rev. 1*, <http://unfccc.int/resource/docs/2015/cop21/eng/l09r01.pdf>.
- Vaccaro, A., Velotto, G., and Zobia, A. F. (2011). A decentralized and cooperative architecture for optimal voltage regulation in smart grids. *IEEE Trans. on Industrial Electronics*, **58** (10), pp. 4593–4602.
- Wang, C., Grebogi, C., and Baptista, M. S. (2016). Control and prediction for blackouts caused by frequency collapse in smart grids. *Chaos*, **26** (9), pp. 093119.
- Wei, J., Kundur, D., Zourntos, T., and Butler-Purry, K. (2012). A flocking-based dynamical systems paradigm for smart power system analysis. In *2012 IEEE Power and Energy Society General Meeting*, IEEE, pp. 1–8.
- Weitenberg, E., Jiang, Y., Zhao, C., Mallada, E., De Persis, C., and Dörfler, F. (2018). Robust decentralized secondary frequency control in power systems: Merits and tradeoffs. *IEEE Trans. on Automatic Control*, **64** (10), pp. 3967–3982.
- Witthaut, D., Rohden, M., Zhang, X., Hallerberg, S., and Timme, M. (2016). Critical links and nonlocal rerouting in complex supply networks. *Phys. Rev. Lett.*, **116** (13), pp. 138701.